

## 2020 CERTIFICATION

### Consumer Confidence Report (CCR)

Town

OF

GLASTON

Public Water System Name

0030003

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

#### CCR DISTRIBUTION (Check all boxes that apply.)

##### INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)

- ☒ Advertisement in local paper (Attach copy of advertisement)
- ☐ On water bills (Attach copy of bill)
- ☐ Email message (Email the message to the address below)
- ☐ Other \_\_\_\_\_

DATE ISSUED

May 20, 2021

##### DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)

- ☐ Distributed via U. S. Postal Mail
- ☐ Distributed via E-Mail as a URL (Provide Direct URL): \_\_\_\_\_
- ☐ Distributed via E-Mail as an attachment
- ☐ Distributed via E-Mail as text within the body of email message
- ☐ Published in local newspaper (attach copy of published CCR or proof of publication)
- ☐ Posted in public places (attach list of locations)
- ☐ Posted online at the following address (Provide Direct URL): \_\_\_\_\_

DATE ISSUED

#### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name

Mary de la Sancha

Title

John Chene

Date

May 28, 2021

#### SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

Email: [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

Fax: (601) 576-7800

(NOT PREFERRED)

**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

2020 Annual Drinking Water Quality Report  
 Town of Gloster  
 PWS#: 0030003  
 May 2021

2021 MAY 13 AM 8:11

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Miocene Series Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Gloster have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Gary Sterling at 601.657.0478. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 5:30 PM at the Gloster Town Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2020	.0382	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2017/19*	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

17. Lead	N	2017/19*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2020	.61	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	N	2019*	3900	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

### Disinfection By-Products

Chlorine	N	2020	1.3	1.2 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	-----------	------	---	----------	---

*\* Most recent sample. No sample required for 2020*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Town of Gloster works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

STATE OF MISSISSIPPI

COUNTY OF AMITE

PERSONALLY CAME before me, the undersigned, a notary public in and for the state aforesaid, the

Annual Drinking Water Quality Report

Town of Gloster

PWS#: 0030003

May 2021

This report is designed to inform you about the quality water and services we deliver to you every day. Our water. We want you to understand the efforts we make to continually improve the water treatment process our water. Our water source is from three wells from the Miocene Series Aquifers.

Item to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. Terminations were made has been furnished to our public water system and is available for viewing upon ability ranking to contamination.

Please contact Gary Sterling at 601-657-0478. We want our valued customers to be informed about their led meetings. They are held on the first Tuesday of each month at 5:30 PM at the Gloster Town Hall.

Federal and State laws. This table below lists all of the drinking water contaminants that we detected during ng wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of ses, radioactive materials and can pick up substances or contaminants from the presence of animals or it may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; ing or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas pro- a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical products of industrial processes and petroleum production, and can also come from gas stations and sepe- he result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, r provided by public water systems. All drinking water, including bottled drinking water, may be reasonably t to remember that the presence of these contaminants does not necessarily indicate that the water poses

familiar with. To help you better understand these terms we've provided the following definitions:

rs treatment or other requirements which a water system must follow.

highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as

of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow

fectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary

ng water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the

responds to one minute in two years or a single penny in \$10,000.

ds to one in minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

MCLG	MCL	Likely source of Contamination
2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
0	AL=15	Corrosion of household plumbing systems; erosion of

undersigned agent of THE SOUTHERN HERALD, a newspaper published in the Town of Liberty, Amite County, Mississippi, who, being duly sworn, deposes and says that THE SOUTHERN HERALD is a newspaper as defined and prescribed in Section 13-3-3, Mississippi Code of 1972, and that the publication of

202 ANNUAL DRINKING WATER QUALITY REPORT

TOWN OF GLOSTER

PWS#: 0030003

MAY 2021

of which the annexed is a copy, has been made in said paper 1 times consecutively, to-wit:

On the 20 day of MAY, 2021

On the        day of       , 2021

On the        day of       , 2021

On the        day of       , 2021

*[Signature]*

Publisher

SWORN TO and subscribed before me, this

20 day of MAY, 2021

*[Signature]*

Notary Public

My Commission Expires MARCH 12, 2023

PUBLISHER'S FEE

4 Col. X 15 In. @ \$7.00 = \$360.00

Making Proof of Publication        \$0.00

TOTAL        \$360.00

